




# Navy Techval Program



**Techval**

**FUPWG**

October 20, 2010

Rapid City, SD

Paul Kistler, PE CEM

NAVFAC Engineering Service Center

Port Hueneme CA

## Technologies

- **Work Station Specific Lighting**
- **CO2 HVAC control**
  - What is it, how does it work?
  - Data from projects
  - Where does it work best?

# Work Station Specific Lighting



## What Is It?

1. Pendant light used mainly in open cubicles
2. Each cubicle has own dedicated fixture
3. One up light
4. Two down lights
5. Down light dimmed by the occupant
6. Up light on time clock
7. Occupancy sensor
8. Day light sensor
9. T5 5000K
10. Does not replace task lighting



# Work Station Specific Lighting


## Projected Savings

1. Projected payback is 17 years
2. Projected pay back on incremental cost is 3 to 4 years
3. Recent projects indicate a total savings of 70% lighting energy use
4. Most of the savings due to occupancy sensor


## Challenges

1. Building new in 1996.
2. Originally 3 lamp T8 2 X 4 recessed troffer, est. 50 FC
3. Nine foot ceilings
4. During California energy crises, severely delamped
  - a) 21 fixtures with 0 lamps
  - b) 23 fixtures with 1 lamp
  - c) 10 fixtures with 2 lamps
  - d) 0 fixtures with 3 lamps
  - e) Average 12 FC, 0.4 min, 42 max
5. New occupants relamped their area and changed cubicle spaces and heights
6. Timeclock, on 0600, off 1800. Reset 2 hours.
7. Two banks of lights per circuit


The lighting level is set at the preferred level for the work that I do



# The overhead lighting makes it difficult for me to read printed material




# The overhead lighting is acceptable







# The overhead lighting is too dim for the work that I do




## The overhead lighting allows me to see comfortably




## The overhead lighting is pleasant to work under



# The overhead lighting is too high for the work that I do



Overall, how would you rate the existing overhead lighting?




# Work Station Specific Lighting




## Issues

- **Mounting height**
  - 20" from ceiling to top of fixture
  - 7'1" from floor to bottom of fixture
  - Hot spots on ceiling
  - Fire sprinklers
- **Uniformity in passageways**
- **Shadows on work area**
- **Commissioning**
  - Not a DIY
- **Uplight**
  - Hot spots
  - Glare
- **Navy IT security**
- **Change out remaining lighting to 5000K**

**Lighting Circuits 1 & 2 Power Use Monday, 6/7/10 - Sunday, 6/20/10**




## Lighting Circuits 1 & 2 Power Use 6/18/10






# Lighting Circuits 1 & 2 Power Use 8/13/10



# Lighting Circuits 1 & 2 Power Use Tuesday 9/7/10 - Tuesday 9/21/10



# Tabulated Data




Original		
	Circuit 1	Circuit 2
Min W	6	12
Max W	1609	1605
Ave W	652	729
Post Install		
	Circuit 1	Circuit 2
Min W	248	219
Max W	1441	1165
Ave W	545	454

## **Tabulated Illumination Data After New Lighting Install**

Min	6 FC
Max	32 FC
Ave	16 FC


## Illumination Measurements After New Lighting



# Light Right Consortium Lighting Satisfaction Survey Tool




I am satisfied with my ability to control my overhead lighting.




# Light Right Consortium Lighting Satisfaction Survey Tool



## Reading from a computer screen




# Light Right Consortium Lighting Satisfaction Survey Tool







# Light Right Consortium Lighting Satisfaction Survey Tool




# Light Right Consortium Lighting Satisfaction Survey Tool



# Light Right Consortium Lighting Satisfaction Survey Tool




# Light Right Consortium Lighting Satisfaction Survey Tool



# Light Right Consortium Lighting Satisfaction Survey Tool




Direct glare from the light fixtures  
beyond your immediate workspace  
(the light fixtures appear too bright)



# Light Right Consortium Lighting Satisfaction Survey Tool




What is the color appearance  
of the lighting in your personal  
workspace?



# Light Right Consortium Lighting Satisfaction Survey Tool



What would you prefer for the color appearance of the lighting in your personal workspace?



# Light Right Consortium

## Lighting Satisfaction Survey Tool



[carol.jones@pnl.gov](mailto:carol.jones@pnl.gov)

[www.lightright.org](http://www.lightright.org)

[www.lightingsolutions.energy.gov](http://www.lightingsolutions.energy.gov)



# Work Station Specific Lighting



## Where to use

1. Open cubicles
2. Cubicles are frequently unoccupied
3. Daylight in outer zones
4. Large number of people that perform various visual tasks
5. Various age ranges

# CO<sub>2</sub> HVAC Control



- How can you determine if active CO<sub>2</sub> control via your ventilation system is a legitimate option for your facility?
- What are the acceptable levels of ventilation and how are they determined?
- Why should you bother? – economic and energy incentives
- Three case studies – Virginia, Tennessee, Washington

# CO<sub>2</sub> HVAC Control



## What is it?

Reduces the amount of outside air brought into a building based on the CO<sub>2</sub> level in the building.

# Is CO<sub>2</sub> Control for You?



- Does your HVAC system incorporate an economizer control system?
- Do summertime temperatures get above 85 degrees?
- Do wintertime temperatures get below 45 degrees?
- Is the cost of heating fuel greater than \$11.50/MBTU?
- Is the cost of electricity greater than \$0.08/kWh?
- Is there less than 30 ft<sup>2</sup>/person in the HVAC zone when fully occupied?
- Is the HVAC zone less than fully occupied 40% or more of the time?

# Acceptable Levels of Ventilation



- **ASHRAE Standard 62**
  - Sets minimum outside air volumetric flow rates (cfm) based upon number of occupants within space, square footage of space, and effectiveness of the ventilation system serving the space
  - Outside air amounts target the amount necessary to maintain CO<sub>2</sub> levels within the space at no more than 700 ppm above outside air levels (Appendix C of Standard 62)
- **UFC Guidelines - Federal**
  - Primarily refer to ASHRAE standards
- **State and Local Guidelines**

# Why bother? – economic and energy incentives



- **Conditioning of ventilation air can account for as much as 50% of the energy requirements of HVAC systems in many climates**
- **Any reduction in the amount of ventilation air to be processed results in a decrease in energy consumption**
- **Any decrease in energy consumption results in an economic savings**

# Three Case Studies



- **Virginia – Naval Amphibious Base Little Creek**
  - Norfolk, VA
  - Building 3607, Galley
- **Tennessee – Naval Support Activity, Mid-South**
  - Millington, TN
  - Building 767, Conference Center
- **Washington – Naval Base Kitsap**
  - Bremerton, WA
  - Building 1017, Gymnasium

# Virginia - Little Creek Building 3607 Galley








# Performance Results - Virginia




- **Occupancy Schedule**
- **CO2 Measured Concentration Levels**
- **Ventilation Air Cooling Load**
- **Ventilation Air Heating Load**
- **Ventilation Air Flow Rate**


# Occupancy Schedule - Virginia



# CO<sub>2</sub> Measured Concentration Levels - Virginia




# Ventilation Air Cooling Load - Virginia




# Ventilation Air Heating Load - Virginia



AHU-1 OSA HEATING (BASELINE & CO<sub>2</sub> CONTROL) - LITTLE CREEK



# Ventilation Air Flow Rates - Virginia




# Performance Results – All Sites




- **CO<sub>2</sub> Controlled Hours**
- **Savings per CO<sub>2</sub> Controlled Hour**
- **Annual Savings**
- **Payback in Years – non weather corrected**
- **Energy Manager Decision Calculator**
- **Test Site Evaluation Scores**
- **Payback based on Evaluation Scores**




# CO<sub>2</sub> Controlled Hours – All Sites



# Savings per CO<sub>2</sub> Controlled Hour – All Sites



# Annual Savings – All Sites



# Payback in Years – All Sites Non Weather Corrected



	<b>Total Installed Cost</b>	<b>Annual Total Savings</b>	<b>Payback (yrs)</b>
<b>Little Creek</b>	\$ 18,373	\$ 7,427	2.5
<b>Mid-South</b>	\$ 35,500	\$ 5,682	6.3
<b>Kitsap</b>	\$ 19,685	\$ 348	56.6

# Energy Manager Decision Calculator

## – Should I Install or Not?



CO <sub>2</sub> HVAC Controls Decision Calculator					
	Score				
Variable	1	2	3	4	5
CDD	<1000	1000 - 1250	1250 - 1750	1750 - 2000	>2000
HDD	<3000	3000 - 4000	4000 - 5000	5000 - 6000	>6000
Cost of heating fuel (per MBTU)	<\$11	\$11 - \$11.50	\$11.50 - \$12	\$12 - \$12.50	>\$12.50
Cost of Electricity (per kWh)	<5¢	5¢ - 6¢	8¢ - 9¢	7¢ - 10¢	>10¢
Efficiency of Heating System	>75%	65% - 75%	55% - 65%	45% - 55%	<45%
COP of Cooling System	>5	4 - 5	3 - 4	2 - 3	<2
Max SF/person in HVAC zone	>60	50 - 60	30 - 50	20 - 30	<20
% of time zone < 50% occupied	<25%	25% - 40%	40% - 55%	55% - 75%	>75%

- If the total score is <19, the candidate facility is not a good candidate for this technology.
- If the total score is 19 - 25, it is definitely worth further investigation.
- If the total score is > 26, it is a strong indicator of a good candidate for this technology.


# Test Site Evaluation Scores



- For the three sites included in this evaluation, the scores are:

Variable	Kitsap		Little Creek		Mid-South	
	Value	Score	Value	Score	Value	Score
CDD	393	1	2108	5	2094	5
HDD	4784	3	3066	2	3542	2
Cost of heating fuel (per MBTU)	\$10.51	1	\$12.08	4	\$12.41	5
Cost of Electricity (per kWh)	\$0.04	1	\$0.03	1	\$0.09	4
Efficiency of Heating System	0.8%	1	0.35%	5	0.8%	1
COP of Cooling System	3.5	3	3.5	3	3.5	3
Max SF/person in HVAC zone	100	1	15	5	20	4
% of time zone < 50% occupied	0.25%	1	0.8%	5	0.6%	4
<b>Totals</b>		<b>12</b>		<b>30</b>		<b>28</b>

# Payback Based on Evaluation Score



# CO2 HVAC Control Maintenance Issues



- **Recalibrate every 5 years**
- **Internal algorithm in each sensor to minimize sensor drift between recalibrations**
- **\$500 for recalibration kit**



# Contact Information




**Paul Kistler P.E. C.E.M.  
Mechanical Engineer  
NAVFAC Engineering Service Center  
1100 23rd Ave.  
Port Hueneme CA 93043  
(805) 982-1387  
Paul.kistler@navy.mil**

# Light Right Consortium Lighting Satisfaction Survey Tool




The lighting fixtures in the general office area around my workspace are nice-looking.



# Light Right Consortium Lighting Satisfaction Survey Tool




My skin is an unnatural tone  
under the lighting.



# Light Right Consortium Lighting Satisfaction Survey Tool




## Filing or locating papers



# Light Right Consortium Lighting Satisfaction Survey Tool




## Face to face conversations




# Light Right Consortium Lighting Satisfaction Survey Tool




Glare reflected from your work surface



# Light Right Consortium Lighting Satisfaction Survey Tool



# Light Right Consortium Lighting Satisfaction Survey Tool







# Light Right Consortium Lighting Satisfaction Survey Tool




Glare from the light fixtures  
reflected on your computer  
screen



# Light Right Consortium Lighting Satisfaction Survey Tool




# Light Right Consortium Lighting Satisfaction Survey Tool



# Light Right Consortium Lighting Satisfaction Survey Tool



## "Burning" or tired eyes after using computer extensively



# Light Right Consortium Lighting Satisfaction Survey Tool



I have to take a break to let  
my eyes recover

